

Building ID	Sample Date	Sample Time (12 HR Clock)	Sample Location Description	Concentration (ug/L)	Notes
North Elem.	8/4/17	6:59 AM	01 KS by Refrigerator	4.5	At Level
North Elem.	8/4/17	7:00 AM	01A KS Flush by Refrigerator	2.0	At Level
North Elem.	8/4/17	7:01 AM	02 KS Food Prep by Microwave	7.8	Above Level
North Elem.	8/4/17	7:02 AM	02A KS Flush Food Prep by Microwave	1.0	At Level
North Elem.	8/4/17	7:06 AM	03 DF West by Gym	< 1.0	Below Level
North Elem.	8/4/17	7:07 AM	03A DF West Flush by Gym	1.3	At Level
North Elem.	8/4/17	7:10 AM	04 DF East Upper by Gym	< 1.0	Below Level
North Elem.	8/4/17	7:11 AM	05 DF East Lower by Gym	< 1.0	Below Level
North Elem.	8/4/17	7:12 AM	05A DF East Lower Flush by Gym	< 1.0	Below Level
North Elem.	8/4/17	7:17 AM	06 DF Back Hallway Upper	< 1.0	Below Level
North Elem.	8/4/17	7:19 AM	06A DF Flush Back Hallway Upper	< 1.0	Below Level
North Elem.	8/4/17	7:18 AM	07 DF Back Hallway Lower	< 1.0	Below Level
North Elem.	8/4/17	7:22 AM	08 DF West Upper by Rm 141	< 1.0	Below Level
North Elem.	8/4/17	7:24 AM	08A DF West Upper Flush by Rm 141	2.1	At Level
North Elem.	8/4/17	7:23 AM	09 DF West Lower by Rm 141	20.8	Above Level
North Elem.	8/4/17	7:31 AM	10 DF East Upper by Rm 141	< 1.0	Below Level
North Elem.	8/4/17	7:32 AM	11 DF East Lower by Rm 141	< 1.0	Below Level
North Elem.	8/4/17	7:33 AM	11A DF East Lower Flush by Rm 141	< 1.0	Below Level
North Elem.	8/4/17	7:39 AM	12 DF Upper by Office	< 1.0	Below Level
North Elem.	8/4/17	7:40 AM	13 DF Lower by Office	< 1.0	Below Level
North Elem.	8/4/17	7:41 AM	13A DF Lower Flush by Office	< 1.0	Below Level